

INSTALLATION

!CAUTION!

• *This product is not intended for life or safety applications*

Severe injury or death can result from electrical shock during contact with high voltage conductors or related equipment. Disconnect and lock-out all power sources during installation. Applications shown are suggested means of installing relays, but it is the responsibility of the installer to ensure that the installation is in compliance with all national and local codes. Installation should be attempted only by individuals familiar with codes, standards, and proper safety procedures for high-voltage installations. Do not rely on status indications of device exclusively to determine if power is present in conductor.

Ensure load and coil source are shut off and locked out before installation

- Using the threaded nipple connect the V120 to the desired enclosure through a knock out.
- Secure with the conduit nut provided.
- Connect Coil:
 - Choose the coil common lead (White with Yellow stripe) and connect it to the (-) source termination point.
 - Choose either the low (24VAC/DC White w/blue stripe) or high (120VAC White w/black stripe) voltage lead whichever fits your application and connect it to the (+) source termination point.*
- Connect Relay Contacts:
 - Choose the Relay Common Wire (Yellow) and connect to switched load.
 - Choose the Relay N.O. (Orange) and/or* N.C. (Blue) lead and connect to switched load.

- Secure your enclosure and reconnect power.

*Wires which are not terminated must be isolated or insulated, e.g. wire nut.

SPECIFICATIONS

General

Operating Temp..... -34°C to 55°C
 Operating Humidity 0-95% non condensing
 Expected Relay Life 10 million cycles min. mechanical
 Relay Status..... LED ON=energized
 Dimensions..... 2.92"(L)X1.80"(W)X1.58"
 (H) 1/2" NPT nipple

TYPICAL COIL PERFORMANCE

Coil Current (Typical)	Voltage
32mA@.....	24VDC
75mA@.....	24VAC
42mA@.....	120VAC

CONTACT RATINGS

Resistive..... 20A(r)@277VAC, 28VDC
 Motor..... 120VAC, 1 HP
 277VAC, 2 HP
 Ballast..... 20A@277VAC N.O. / 10A N.C.
 Tungsten..... 10A@120VAC N.O. / 2A N.C.
 Pilot Duty.... A300

Installation Instructions

Victory 120 SPDT Enclosed Relay


VERIS INDUSTRIES



PORTLAND, OREGON USA
 (503) 598-4564 FAX (503) 598-4664
 1-800-354-8556


http://www.veris.com email:sales@veris.com

WIRE COLORS




WIRING EXAMPLES

Nipple Mount directly to a Panel



Nipple Mount to any 2X or 4X Box



*Any unused wires must be isolated, i.e. wire nut.